

TERMINAL STRIP TB-3							
Device1	Pin1	Number	Jumper	Manufacturer	Catalog	Device2	Pin2
		ANCHOR		AUTOMATION-DIRECT	DN-EB35		
DV1119	+	5031	○ ○ ○	AUTOMATION-DIRECT	DN-T10	TB-3	5031
TB-3	5031		● ○ ○				
DV1123	+	5031	○ ○ ○	AUTOMATION-DIRECT	DN-T10	TB-3	5031
TB-3	5031		● ○ ○				
DV1127	+	5031	○ ○ ○	AUTOMATION-DIRECT	DN-T10	MPC542	13
TB-3	5031		● ○ ○				
DV1144	+	5031	○ ○ ○	AUTOMATION-DIRECT	DN-T10	TB-3	5031
			● ○ ○				
PLC1101		11051	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1101	I:8/1	11071	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
DV1119	-	11221	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1101	I:8/4
DV1123	-	11261	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1101	I:8/5
DV1127	-	11301	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1101	I:8/6
PLC11421	O:10/0	11421	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421		11431	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
DV1144	-	11441	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1142	I:9/0
PLC11421	O:10/1	11461	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421		11471	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1142		11472	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1142	I:9/1	11481	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421	O:10/2	11501	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421		11511	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1142		11512	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1142	I:9/2	11521	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421	O:10/3	11541	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421		11551	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1142		11552	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1142	I:9/3	11561	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421	O:10/4	11581	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421		11591	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421	O:10/6	11661	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421		11671	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421	O:10/7	11701	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC11421		11711	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
		ANCHOR		AUTOMATION-DIRECT	DN-EB35		

TERMINAL STRIP TB-2A							
Device1	Pin1	Number	Jumper	Manufacturer	Catalog	Device2	Pin2
		ANCHOR		AUTOMATION-DIRECT	DN-EB35		
LS1201	2	12011	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/0
LS1203	2	12031	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/1
LS1205	2	12051	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/2
LS1207	2	12071	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/3
LS1209	2	12091	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/4
LS1211	2	12111	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/5
LS1213	2	12131	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/6
LS1215	2	12151	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/7
LS1217	2	12171	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/8
LS1219	2	12191	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/9
LS1221	2	12211	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/10
LS1223	2	12231	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/11
LS1225	2	12251	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/12
LS1227	2	12271	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/13
LS1229	2	12291	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/14
LS1231	2	12311	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1201	I:11/15
LS1242	2	12421	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1242	I:12/0
LS1244	2	12441	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1242	I:12/1
LS1246	2	12461	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1242	I:12/2
LS1248	2	12481	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1242	I:12/3
LS1250	2	12501	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1242	I:12/4
LS1252	2	12521	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1242	I:12/5
LS1254	2	12541	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1242	I:12/6
LS1256	2	12561	○ ○ ○	AUTOMATION-DIRECT	DN-T10	PLC1242	I:12/7
PLC1242	I:12/8	12581	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1242	I:12/9	12601	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1242	I:12/10	12621	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1242	I:12/11	12641	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1242	I:12/12	12661	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1242	I:12/13	12681	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1242	I:12/14	12701	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
PLC1242	I:12/15	12721	○ ○ ○	AUTOMATION-DIRECT	DN-T10		
		ANCHOR		AUTOMATION-DIRECT	DN-EB35		

REV-E

3985 Commerce Drive, St. Charles, IL 60174 www.hydrofotech.com			
<small>THIS DRAWING IS THE PROPERTY OF HYDRO-FLO TECHNOLOGIES, INC. AND IS LOANED UPON THE EXPRESS CONDITION THAT IT SHALL NOT BE COPIED OR REPRODUCED IN ANY MANNER, THAT IT SHALL NOT BE SUBMITTED TO OTHERS FOR EXAMINATION WITHOUT THE CONSENT OF THIS COMPANY, THAT IT SHALL NOT BE USED IN ANY OTHER WAY DETRIMENTAL TO THE INTERESTS OF THIS COMPANY AND THAT IT SHALL BE RETURNED UPON DEMAND.</small>			
P2511 SYSTEM PANEL			
TOLERANCES UNLESS NOTED: 0.015" ALL DIMENSIONS IN INCHES	SCALE: NONE	DRAWN: 000	DATE: 12/3/07
APPRVD:	DATE:	DRAWING NUMBER	SHT NO:
JOB	CUSTOMER	07-2809	07-2809-E01 170F20

F	7/29/09	REVISE PER FIELD MODIFICATIONS
E	4/6/09	REVISE PER FIELD MODIFICATIONS
D	2/26/09	ADD VLV-600 AND VLV-601
C	8/20/08	AS BUILT
B	5/29/08	REVISE PER COMMENTS 5/23/08
A	2/15/08	REVISE PER COMMENTS 2/11/08
REV	DATE	CHANGES