

ITEM #	TAGS	QTY	CATALOG	MFG	DESCRIPTION
	FU349	1	6J60A3B	MARATHON	3-POLE FUSEBLOCK 60 AMP CLASS-J 600 VAC 60 AMP 3-POLE
	RECPT470	1	86401	MULBERRY	COVER GFCI COVER 15A
	DUCT	2	C1WH6	PANDUIT	WIRING DUCT COVER 1" WIDE COVER WHITE
	DUCT	6	C2WH6	PANDUIT	WIRING DUCT COVER 2" WIDE COVER WHITE
	DUCT	1	C3WH6	PANDUIT	WIRING DUCT COVER 3" WIDE COVER WHITE
	DUCT	2	G1X3WH6	PANDUIT	WIRING DUCT 1" WIDE X 3" TALL G SERIES SLOTTED WHITE
	DUCT	6	G2X3WH6	PANDUIT	WIRING DUCT 2" WIDE X 3" TALL G SERIES SLOTTED WHITE
	DUCT	1	G3X3WH6	PANDUIT	WIRING DUCT 3" WIDE X 3" TALL G SERIES SLOTTED WHITE
	VFD228	1	ATV31H037N4	SQUARE-D	480VAC VFD 1/2HP COMPACT DRIVE 480VAC 1/2HP ALTIVAR31 380-500VAC 3-PHASE INPUT 3-PHASE OUTPUT 1/2 HP
	VFD349	1	ATV31HD11N4	SQUARE-D	480VAC VFD 15HP COMPACT DRIVE 480VAC 15HP ALTIVAR31 480VAC 3-PHASE INPUT 3-PHASE OUTPUT 15 HP
	VFD202 VFD215	2	ATV31HU15N4	SQUARE-D	480VAC VFD 2HP COMPACT DRIVE 480VAC 2HP ALTIVAR31 480VAC 3-PHASE INPUT 3-PHASE OUTPUT 2 HP
	GROUND BAR	1	PK7GTA	SQUARE-D	GROUND BAR 7-POLE GROUND BAR SUITABLE FOR #14-#4 COPPER WIRE OR 2 #14/#12 COPPER WIRE
	ACR208 ACR221 ACR234	3	KDRA1L	TCI	LINE REACTOR 2HP OPEN FRAME 2HP 3% AT 480VAC 3-PHASE UPTO 2HP
	ACR349	1	KDRB2L	TCI	LINE REACTOR 15HP OPEN FRAME 15HP 3% AT 480VAC 3-PHASE UPTO 15HP
	AH643	1	31T115S	WHEELLOCK	AUDIBLE HORN NEMA-4X HORN 120 VAC
	AH643	1	WBB-S	WHEELLOCK	AUDIBLE HORN WHEATHER PROOF BOX FOR 31T115S HORN

**HYDROFLO** TECHNOLOGIES INC.  
3985 Commerce Drive, St. Charles, IL 60174  
www.hydrofotech.com

THIS DRAWING IS THE PROPERTY OF HYDRO-FLO TECHNOLOGIES, INC. AND IS LOANED UPON THE EXPRESS CONDITION THAT IT SHALL NOT BE COPIED OR REPRODUCED IN ANY MANNER, THAT IT SHALL NOT BE SUBMITTED TO OTHERS FOR EXAMINATION WITHOUT THE CONSENT OF THIS COMPANY, THAT IT SHALL NOT BE USED IN ANY OTHER WAY DETRIMENTAL TO THE INTERESTS OF THIS COMPANY AND THAT IT SHALL BE RETURNED UPON DEMAND.

F	7/29/09	REVISE PER FIELD MODIFICATIONS			
E	4/6/09	REVISE PER FIELD MODIFICATIONS			
D	2/26/09	ADD VLV-600 AND VLV-601			
C	8/20/08	AS BUILT			
B	5/29/08	REVISE PER COMMENTS 5/23/08			
A	2/15/08	REVISE PER COMMENTS 2/11/08			
REV	DATE	CHANGES			

P2511 SYSTEM PANEL		TOLERANCES UNLESS NOTED: 1/8" & 1/16"		SCALE: NONE	DRAWN: 000	DATE: 12/3/07
		APPRVD:		DATE:		
JOB	CUSTOMER	DRAWING NUMBER		SHT NO:		
07-2809		07-2809-E01		200F 20		